






FIRE ACTIVITY REPORT

City of Calabasas | April 2024



Advanced Life Support (ALS) Transports: patient transported to hospital in ambulance with paramedic on board;

Basic Life Support (BLS) Transports: patient transported to hospital without paramedic on board



FIRE ACTIVITY REPORT

City of Calabasas | April 2024

FIRE INCIDENTS:

DATE	TYPE	ADDRESS	NOTES	LOSS
04/08/24	Fire, other	4371 OAK GLEN St	Smell of electrical burning inside the home, strongest near the entryway leading to the living room. It was discovered that a portable power storage device in the closet had malfunctioned and began off-gassing. The faulty equipment was then removed from the home.	
04/10/24	Structure Fire	26151 KENROSE Cir	Single family residence with smoke coming from the roof gables. Kenrose IC was established, fire attack and extinguishment performed by FS125 and E68	Property: \$85,000.00 Contents: \$0.00
04/10/24	Fire, other	5916 LAS VIRGENES Rd	Dryer fire in one unit of a two-story apartment. Residents used a fire extinguisher before FD arrival, FFs utilized a water can for final extinguishment, cooling down of dryer and surrounding closet materials.	Property: \$1,500.00 Contents: \$250.00
04/11/24	Brush Fire	26520 AGOURA Rd	Grass fire, approx. 0.01 acres, was extinguished upon FD arrival.	
04/15/24	Vehicle Fire	NB 101 NO Pkwy CALABASAS	Passenger vehicle on fire, extinguished by E68 and E125.	
			TOTAL:	Property: \$86,500.00 Contents: \$250.00

OTHER INCIDENTS:

DATE	TYPE	ADDRESS	NOTES	LOSS
04/02/24	Haz Cond	27050 AGOURA Rd	Gas leak (natural gas or LPG)	
04/07/24	Haz Cond	SB 101 NO Pkwy CALABASAS	Hazardous condition, other	
04/16/24	Haz Cond	26260 ALIZIA CANYON Dr	Gas leak (natural gas or LPG)	
04/28/24	Haz Cond	25305 PRADO DE LA LUNA	Heat from short circuit (wiring), defective/worn	

- 14 Snake related calls in April