

Response to Questions October 30, 2024

RFI 1

1. Where is the City-Provided Design for Curbs?	Design for curb ramps has not been completed and will be provided to the contractor after award. Design will range from standard to specific pending the existing conditions.
2. What are the concrete specifications?	Concrete Specifications are provided in Section 702 of the Specs Package.
3. What is the City's requirement for rebar?	There is no rebar to be installed in sidewalk.